

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1488-CPR-0895/W

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Smoke and heat control ventilator (Fan) ASE

with fire resistance class according to EN 13501-4:2016:

F₂₀₀ 120 F₃₀₀ 60 F₄₀₀ 120

general identification, intended use and performance of the product are described
in the Annex No. Z-1488-CPR-0895/W
which is an integral part of this certificate

placed on the market under the name or trade mark of:

VENTURE INDUSTRIES Sp. z o.o.
ul. Mokra 27
05-092 Łomianki – Kielpin
Poland

and produced in the manufacturing plants:

VENTURE INDUSTRIES Sp. z o.o. ul. Mokra 27 05-092 Łomianki-Kielpin Poland	VENTURE INDUSTRIES Sp. z o.o. Oddział Grudziądz ul. Lotnicza 21A 86-300 Grudziądz Poland
--	---

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 29.10.2020 (updated on 06.06.2024) and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

DEPUTY HEAD
of the Certification Department



Magdalena Wójtowicz, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej



Anna Panek, M.Sc. Eng.

Warsaw, 06.06.2024

Annex No. Z-1488-CPR-0895/W page 1/1
which is an integral part of the certificate No. 1488-CPR-0895/W

Smoke and heat control ventilator (Fan) ASE

Essential characteristics and performances of the product acc. to EN 12101-3:2015

Essential characteristics and performances	Clauses	Levels and/or classes
Operational reliability Application categories Motor rating	4.2.2 4.2.3	Termally uninsulated
		Installation outside the smoke reservoir
		Horizontal or vertical direction of motor shaft
		Converter or direct feed
		Dual purpose use
		H, Δ 105K
Resistance to fire	4.4	F ₂₀₀ 120 F ₃₀₀ 60 F ₄₀₀ 120
Durability of operational reliability	4.6	H, Δ 105K

Intended use:

Fire safety

Detailed identification, scope and conditions of use:

Classification report no. 02313/19/Z00NZZP issued on 07.08.2020

Errata to the classification report no. 02313/19/Z00NZZP issued on 28.03.2024

DEPUTY HEAD
of the Certification Department



Magdalena Wójtowicz, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej



Anna Panek, M.Sc. Eng.



**INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT**

ul. FILTROWA 1, 00-611 WARSZAWA
tel.: +48 (22) 57 96 167, +48 (22) 57 96 168
e-mail: certyfikacja@itb.pl, www.itb.pl

CERTIFICATION MARK

The company:

VENTURE INDUSTRIES Sp. z o.o.
ul. Mokra 27
05-092 Łomianki – Kiełpin
Poland

being the manufacturer of the product:

Smoke and heat control ventilator (Fan) ASE

is authorized to use
the ITB certification mark „WYRÓB BUDOWLANY”
during the period of validity of the certificate no. 1488-CPR-0895/W



1488-CPR-0895/W

DEPUTY HEAD
of the Certification Department

Magdalena Wójtowicz, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Warsaw, 06.06.2024