

1. Unique identification code of the product type:

Regulation (EU) No 205/2011 of the European Parliament and of the Council, Annex IV, Item 10 – Fixed firefighting equipment (fire alarm/detection, fixed firefighting, fire and smoke control and explosion suppression product).

Powered smoke and heat control ventilator type ASE

Classified: F₂₀₀120, F₃₀₀60, F₄₀₀120 (in accordance with PN-EN 13501-4:2016-07)

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):

Name: Powered smoke and heat control axial ventilator

Type: ASE DN 1120-1250

Model and serial number: all manufactured

3. Intended use or uses of the construction product in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Bifunctional device of fire protection for extraction of smoke and hot gases which operates in general ventilation and during fire.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5)

Venture Industries Sp. z o.o.

27 Mokra st.

05-092 Łomianki-Kielpin

Poland

5. . Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

Notified body: BUILDING RESEARCH INSTITUTE, CERTIFICATION DEPARTMENT, ul. Filtrowa 1, 00-611, Warsaw, Poland, Notified body no. 1488 – according to following elements of System 1:

-determining the product type on the basis of type testing (including sampling) and descriptive documentation of the product;

-initial inspection of the manufacturing plant and factory production control

-continuous surveillance, assessment and evaluation of factory production control

Issued the Certificate of Constancy of Performance **No. 1488-CPR-0895/W**

8. In case of the declaration of performance concerning a construction product, for which technical assessment was issued

Not applicable

Signed and on behalf of the manufacturer by:

Wojciech Stawski - Director
(name, job position)

Kielpin 29.10.2020
(place and date of issue)



(signature)

VI_001-CPR-2020
(document No.)

1 of 2
(page No.)

9. Declared performance

Lp.	Essential characteristics of the product	Harmonized technical specification EN 12101-3:2015	Essential characteristics
1.	Application categories Motor rating	4.2.2 4.2.3	Uninsulated
			Adapted to work outside the smoke tank
			Adapted to work in vertical and horizontal position
			Converter-powered (powered by frequency converter) or powered directly (without changing the speed)
			Dual-purpose
			Class of motor insulation H, ΔT 105K
2.	Resistance to fire	4.4	F ₂₀₀ 120; F ₃₀₀ 60; F ₄₀₀ 120;
3.	Durability of operational reliability	4.6	H2, Δ 105K

10. The performance of the product identified in points 1 and is in conformity with declared performance in point 9.

This declaration of performance is issued under sole responsibility of the manufacturer identified in point 4.

Signed and on behalf of the manufacturer by:

Wojciech Stawski - Director
(name, job position)

Kielpin 29.10.2020
(place and date of issue)


(signature)

VI_001-CPR-2020
(document No.)

2 of 2
(page No.)